



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY COMPLIANCE SUMMARY REPORT



Date 8/16/23

Wheel Plant Wheelabrator North Andover
Unit 1 Unit Unit 1
Outlet Source Outlet

Date	Hour	On-Line Minutes	O2		NOx		SO2					CO			Carbon Feed		FF Temp (deg F)		Steam KLbs/Hr		
			Out Vol % Dry	Status	Outlet ppm 7%O2	Status	Outlet ppm 7%O2	Status	Inlet ppm 7%O2	Status	Removal	Status	Outlet ppm 7%O2	Status	4 Hr Block	Status	Lbs/Hr Avg.	8 Hr Block	1 Hr Avg.	4 Hr Block	1 Hr Avg.
8/16/2023	0	60	10.2		139		3		63		95		0			15		309		167.7	
8/16/2023	1	60	10.4		141		11		79		86		0			14		310		166.7	
8/16/2023	2	60	10.4		141		10		71		86		0			14		309		166.7	
8/16/2023	3	60	10.4		141		3		60		94		0	0		13		309	309	166.1	166.8
8/16/2023	4	60	10.3		146		3		55		95		0			14		310		167.6	
8/16/2023	5	60	10.5		139		10		72		87		0			14		309		166.4	
8/16/2023	6	60	10.4		143		2		52		97		0			14		309		164.5	
8/16/2023	7	60	10.7		140		12		82		86		1	0		14	14	309	309	166.4	166.2
8/16/2023	8	60	10.9		141		6		49		88		0			14		310		163.7	
8/16/2023	9	60	10.7		140		7		57		87		0			13		309		168.3	
8/16/2023	10	60	10.7		142		9		69		82		0			14		309		166.9	
8/16/2023	11	60	10.2		141		4		74		95		0	0		14		310	309	165.2	166.0
8/16/2023	12	60	10.1		142		2		71		97		0			14		310		167.0	
8/16/2023	13	60	10.2		138		0		53		100		0			14		309		166.4	
8/16/2023	14	60	10.8		130		0		50		99		0			14		309		168.4	
8/16/2023	15	60	10.1		144		13		85		85		0	0		14	14	310	309	166.2	167.0
8/16/2023	16	60	10.2		143		12		68		82		0			14		310		166.9	
8/16/2023	17	60	10.4		140		14		60		77		0			14		309		167.9	
8/16/2023	18	60	10.0		140		9		62		85		0			14		309		167.3	
8/16/2023	19	60	9.9		141		12		76		84		0	0		14		309	309	165.8	167.0
8/16/2023	20	60	10.0		142		14		77		82		0			14		310		167.0	
8/16/2023	21	60	10.2		139		19		98		80		0			14		309		164.2	
8/16/2023	22	60	10.1		141		16		75		78		0			14		310		165.9	
8/16/2023	23	60	9.9		143		16		74		79		0	0		14	14	310	309	168.9	166.5

Average:
Geometric Mean Average:

Limit:

141	5
≤ 150 24-HR Block Avg.	≤ 29 24-HR Geometric Mean

OR

92
≥ 80% Removal Efficiency

see above
≤ 69 ppmc 4-HR Block Average

see above
≥ 12 lb/hr 8-HR. Block Average

see above
≤ 345 °F 4-HR Block Average

see above
≤ 173 klb/hr 4-HR Block Average

Status Flags

- I - Invalid
- B - Bad
- C - Calibration
- M - Maintenance
- F - Offline
- P - Purge
- T - Out of Control
- E - Excluded
- ^ - Startup
- * - Shutdown



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY COMPLIANCE SUMMARY REPORT



Date 8/16/23

Wheel Plant Wheelabrator North Andover
Unit 2 Unit Unit 1
Outlet Source Outlet

Date	Hour	On-Line Minutes	O2		NOx		SO2					CO			Carbon Feed		FF Temp (deg F)		Steam KLbs/Hr		
			Out Vol % Dry	Status	Outlet ppm 7%O2	Status	Outlet ppm 7%O2	Status	Inlet ppm 7%O2	Status	Removal	Status	Outlet ppm 7%O2	Status	4 Hr Block	Status	Lbs/Hr Avg.	8 Hr Block	1 Hr Avg.	4 Hr Block	1 Hr Avg.
8/16/2023	0	60	9.5		141		0		64		100		4			12		310		166.3	
8/16/2023	1	60	9.7		140		0		62		100		3			14		310		167.7	
8/16/2023	2	60	9.8		141		0		56		100		3			14		311		166.6	
8/16/2023	3	60	10.0		136		1		70		99		4	3		14		309	310	161.6	165.5
8/16/2023	4	60	9.7		143		0		55		100		4			13		310		166.7	
8/16/2023	5	60	10.0		139		0		56		100		3			13		311		166.5	
8/16/2023	6	60	10.0		139		0		39		100		4			12		310		165.9	
8/16/2023	7	60	10.0		141		0		38		100		6	4		14	13	310	310	167.1	166.6
8/16/2023	8	60	10.2		138		0		36		100		4			12		310		167.8	
8/16/2023	9	60	10.2		137		0		35		100		5			17		310		167.6	
8/16/2023	10	60	9.6		142		0		68		100		5			21		311		166.7	
8/16/2023	11	60	9.7		139		0		38		100		4	5		12		309	310	163.4	166.4
8/16/2023	12	60	10.1		140		0		43		100		4			25		310		168.1	
8/16/2023	13	60	10.0		141		0		35		100		4			18		310		166.9	
8/16/2023	14	60	9.8		138		1		67		99		6			17		310		166.7	
8/16/2023	15	60	10.2		140		1		43		97		4	5		17	17	310	310	163.0	166.2
8/16/2023	16	60	9.9		141		0		40		100		5			16		310		165.4	
8/16/2023	17	60	10.0		139		0		33		100		5			16		310		167.4	
8/16/2023	18	60	9.6		139		0		48		100		5			16		310		168.0	
8/16/2023	19	60	9.6		139		0		39		100		5	5		16		310	310	166.7	166.9
8/16/2023	20	60	9.7		140		1		60		98		4			17		310		166.0	
8/16/2023	21	60	9.7		140		12		85		86		48			17		310		168.6	
8/16/2023	22	60	9.9		139		2		58		97		5			17		309		167.3	
8/16/2023	23	60	9.9		139		1		48		99		4	15		14	16	310	310	167.8	167.4

Average: Geometric Mean Average:	140	0	OR	100	see above	see above	see above	see above
Limit:	≤ 150 24-HR Block Avg.	≤ 29 24-HR Geometric Mean		≥ 80% Removal Efficiency	≤ 69 ppmc 4-HR Block Average	≥ 12 lb/hr 8-HR. Block Average	≤ 345 °F 4-HR Block Average	≤ 173 klb/hr 4-HR Block Average

Status Flags

- I - Invalid
- B - Bad
- C - Calibration
- M - Maintenance
- F - Offline
- P - Purge
- T - Out of Control
- E - Excluded
- ^ - Startup
- * - Shutdown



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY OPACITY REPORT



Date 16-Aug-2023

Plant Wheelabrator North Andover
Unit Unit 1
Source Outlet

Opacity is a measure of how much soot or smoke may be contained in stack emissions. The more smoke that is contained in the emissions the higher the level of opacity. Continuous opacity monitors located after all of the air pollution control equipment measure the opacity of the emissions from each boiler. Typically the human eye can not detect or see smoke that is less than 5% opacity. You won't see smoke from a modern trash-to-energy plant although in colder weather you will see water vapor condensation, similar to seeing your breath on a cold day. This is not considered opacity. We have a permit limit established by the Massachusetts Department of Environmental Protection of 10% opacity averaged every six (6) minutes.

Limit 10 %

Time (hr)	1-6 min	7-12 min	13-18 min	19-24 min	25-30 min	31-36 min	37-42 min	43-48 min	49-54 min	55-60 min	Average
0	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1
2	1	1	1	1	1	1	1	1	1	1	1
3	1	1	1	1	1	1	1	1	1	1	1
4	1	1	1	1	1	1	1	1	1	1	1
5	1	1	1	1	1	1	1	1	1	1	1
6	3	IC	5	IC	1	1	1	1	1	1	1
7	1	1	1	1	1	1	1	1	1	1	1
8	1	1	1	1	1	1	1	1	1	1	1
9	1	1	1	1	1	1	1	1	1	1	1
10	1	1	1	1	1	1	1	1	1	1	1
11	1	1	1	1	1	1	1	1	1	1	1
12	1	1	1	1	1	1	1	1	1	1	1
13	1	1	1	1	1	1	1	1	1	1	1
14	1	1	1	1	1	1	1	1	1	1	1
15	1	1	1	1	1	1	1	1	1	1	1
16	1	1	1	1	1	1	1	1	1	1	1
17	1	1	1	1	1	1	1	1	1	1	1
18	1	1	1	1	1	1	1	1	1	1	1
19	1	1	1	1	1	1	1	1	1	1	1
20	1	1	1	1	1	1	1	1	1	1	1
21	1	1	1	1	1	1	1	1	1	1	1
22	1	1	1	1	1	1	1	1	1	1	1
23	1	1	1	1	1	1	1	1	1	1	1

Status Flags

I - Invalid C - Calibration F - Offline T - Out of Control ^ - Startup
 B - Bad M - Maintenance P - Purge E - Excluded * - Shutdown



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY OPACITY REPORT



Date 16-Aug-2023

Plant Wheelabrator North Andover
Unit Unit 2
Source Outlet

Opacity is a measure of how much soot or smoke may be contained in stack emissions. The more smoke that is contained in the emissions the higher the level of opacity. Continuous opacity monitors located after all of the air pollution control equipment measure the opacity of the emissions from each boiler. Typically the human eye can not detect or see smoke that is less than 5% opacity. You won't see smoke from a modern trash-to-energy plant although in colder weather you will see water vapor condensation, similar to seeing your breath on a cold day. This is not considered opacity. We have a permit limit established by the Massachusetts Department of Environmental Protection of 10% opacity averaged every six (6) minutes.

Limit 10 %

Time (hr)	1-6 min	7-12 min	13-18 min	19-24 min	25-30 min	31-36 min	37-42 min	43-48 min	49-54 min	55-60 min	Average
0	0	0	0	0	0	0	0	0	0	0	0
1	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0
4	0	0	0	0	0	0	0	0	0	0	0
5	0	0	0	0	0	0	0	0	0	0	0
6	2	IBC	4	IBC	0	0	0	0	0	0	1
7	0	0	0	0	0	0	0	0	0	0	0
8	0	0	0	0	0	0	0	0	0	0	0
9	0	0	0	0	0	0	0	0	0	0	0
10	0	0	0	0	0	0	0	0	0	0	0
11	0	0	0	0	0	0	0	0	0	0	0
12	0	0	0	0	0	0	0	0	0	0	0
13	0	0	0	0	0	0	0	0	0	0	0
14	0	0	0	0	0	0	0	0	0	0	0
15	0	0	0	0	0	0	0	0	0	0	0
16	0	0	0	0	0	0	0	0	0	0	0
17	0	0	0	0	0	0	0	0	0	0	0
18	0	0	0	0	0	0	0	0	0	0	0
19	0	0	0	0	0	0	0	0	0	0	0
20	0	0	0	0	0	0	0	0	0	0	0
21	0	0	0	0	0	0	0	0	0	0	0
22	0	0	0	0	0	0	0	0	0	0	0
23	0	0	0	0	0	0	0	0	0	0	0

Status Flags

I - Invalid C - Calibration F - Offline T - Out of Control ^ - Startup
 B - Bad M - Maintenance P - Purge E - Excluded * - Shutdown