



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY DRAFT - COMPLIANCE SUMMARY REPORT



Date 1/17/25

Plant Wheelabrator North Andover

NOTE: Emission & Process results may change after Startup, Shutdown, Malfunction data validation

Unit Unit 1
Source Outlet

Date	Hour	On-Line Minutes	O2		NOx		SO2					CO			Carbon Feed		FF Temp (deg F)		Steam KLbs/Hr		
			Out Vol % Dry	Status	Outlet ppm 7%O2	Status	Outlet ppm 7%O2	Status	Inlet ppm 7%O2	Status	Removal	Status	Outlet ppm 7%O2	Status	4 Hr Block	Status	Lbs/Hr Avg.	8 Hr Block	1 Hr Avg.	4 Hr Block	1 Hr Avg.
1/17/2025	0	60	11.2		131		1		22		94		1			17		309		165.9	
1/17/2025	1	60	10.9		147		0		11		100		1			16		309		166.6	
1/17/2025	2	60	11.0		192		0		7		100		1			16		309		167.8	
1/17/2025	3	60	11.0		175		0		11		100		1	1		14		310	309	167.2	166.8
1/17/2025	4	60	11.2		151		6		17		66		2			14		309		166.3	
1/17/2025	5	60	11.3		103		15		35		58		2			11		309		168.1	
1/17/2025	6	60	11.2		99		10		44		76		3			10		310		166.3	
1/17/2025	7	60	11.3		137		1		21		93		2	2		14	14	310	309	165.3	166.5
1/17/2025	8	60	11.4		139		3		33		91		1			14		309		166.7	
1/17/2025	9	60	11.2		138		3		41		93		3			14		309		166.8	
1/17/2025	10	60	11.4		142		0		22		100		2			11		309		167.2	
1/17/2025	11	60	11.5		140		3		37		91		1	2		14		310	309	166.9	166.9
1/17/2025	12	60	11.4		143		9		44		80		2			15		308		167.5	
1/17/2025	13	60	10.9		140		1		31		96		44			13		312		166.3	
1/17/2025	14	60	11.1		142		0		23		100		3			14		309		165.0	
1/17/2025	15	60	11.2		141		0		30		100		3	13		11	13	309	310	168.1	166.7
1/17/2025	16	60	11.3		140		0		28		100		1			15		309		167.8	
1/17/2025	17	60	11.3		142		0		33		100		2			15		309		166.4	
1/17/2025	18	60	11.3		141		0		32		100		2			16		309		166.7	
1/17/2025	19	60	11.4		141		0		41		100		1	2		14		309	309	166.0	166.7
1/17/2025	20	60	11.3		143		0		41		100		1			14		310		166.5	
1/17/2025	21	60	11.5		139		4		56		94		1			15		309		166.6	
1/17/2025	22	60	11.4		141		7		76		90		1			15		309		167.9	
1/17/2025	23	60	11.4		135		3		54		95		1	1		15	15	309	309	168.7	167.4

Average:
Geometric Mean Average:

141	1
≤ 150 24-HR Block Avg.	≤ 29 24-HR Geometric Mean

OR

99
≥ 80% Removal Efficiency

see above
≤ 69 ppmc 4-HR Block Average

see above
≥ 12 lb/hr 8-HR. Block Average

see above
≤ 345 °F 4-HR Block Average

see above
≤ 173 klb/hr 4-HR Block Average

Status Flags

- I - Invalid
- B - Bad
- C - Calibration
- M - Maintenance
- F - Offline
- P - Purge
- T - Out of Control
- E - Excluded
- ^ - Startup
- * - Shutdown



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY DRAFT - COMPLIANCE SUMMARY REPORT



Date 1/17/25

Plant Wheelabrator North Andover

NOTE: Emission & Process results may change after Startup, Shutdown, Malfunction data validation

Unit Unit 2

Source Outlet

Date	Hour	On-Line Minutes	O2		NOx		SO2					CO			Carbon Feed		FF Temp (deg F)		Steam KLbs/Hr		
			Out Vol % Dry	Status	Outlet ppm 7%O2	Status	Outlet ppm 7%O2	Status	Inlet ppm 7%O2	Status	Removal	Status	Outlet ppm 7%O2	Status	4 Hr Block	Status	Lbs/Hr Avg.	8 Hr Block	1 Hr Avg.	4 Hr Block	1 Hr Avg.
1/17/2025	0	60	9.8		127		0		44		100		5			13		310		167.1	
1/17/2025	1	60	9.7		144		0		22		100		4			14		310		166.1	
1/17/2025	2	60	9.7		160		0		9		100		3			14		310		167.3	
1/17/2025	3	60	9.7		132		0		10		100		3	4		14		310	310	168.2	167.2
1/17/2025	4	60	9.9		147		0		16		100		4			14		310		167.3	
1/17/2025	5	60	10.0		147		3		23		89		9			14		310		168.3	
1/17/2025	6	60	10.6		130		0		15		99		24			14		309		164.5	
1/17/2025	7	60	10.0		140		0		24		100		5	10		14	14	310	310	166.3	166.6
1/17/2025	8	60	10.5		143		0		28		100		4			14		310		166.1	
1/17/2025	9	60	10.4		134		0		36		100		7			13		310		163.9	
1/17/2025	10	60	10.1		141		0		24		100		5			14		310		167.9	
1/17/2025	11	60	10.0		142		0		28		100		7	6		13		311	310	168.0	166.4
1/17/2025	12	60	10.1		135		0		27		100		6			14		309		165.9	
1/17/2025	13	60	9.7		140		0		20		100		3			14		310		167.6	
1/17/2025	14	60	9.8		141		0		28		100		4			13		310		167.3	
1/17/2025	15	60	9.8		138		0		34		100		5	4		14	14	310	310	168.0	167.2
1/17/2025	16	60	9.7		141		0		27		100		5			14		310		166.8	
1/17/2025	17	60	9.7		139		0		30		100		4			14		310		168.0	
1/17/2025	18	60	9.9		137		0		27		100		3			14		310		168.1	
1/17/2025	19	60	9.9		142		0		41		100		3	4		14		310	310	168.3	167.8
1/17/2025	20	60	10.0		137		1		72		99		4			14		309		167.3	
1/17/2025	21	60	10.0		140		0		65		100		3			14		310		167.0	
1/17/2025	22	60	10.0		141		14		121		89		3			14		310		168.1	
1/17/2025	23	60	10.0		133		0		50		100		2	3		14	14	310	310	167.6	167.5

Average:	140	0	100			
Geometric Mean Average:					see above	see above
Limit:	≤ 150 24-HR Block Avg.	≤ 29 24-HR Geometric Mean	OR	≥ 80% Removal Efficiency	≤ 69 ppmc 4-HR Block Average	≥ 12 lb/hr 8-HR. Block Average
						≤ 345 °F 4-HR Block Average
						≤ 173 klb/hr 4-HR Block Average

Status Flags

- I - Invalid
- B - Bad
- C - Calibration
- M - Maintenance
- F - Offline
- P - Purge
- T - Out of Control
- E - Excluded
- ^ - Startup
- * - Shutdown



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY OPACITY REPORT



Date 17-Jan-2025

Plant Wheelabrator North Andover
Unit Unit 1
Source Outlet

Opacity is a measure of how much soot or smoke may be contained in stack emissions. The more smoke that is contained in the emissions the higher the level of opacity. Continuous opacity monitors located after all of the air pollution control equipment measure the opacity of the emissions from each boiler. Typically the human eye can not detect or see smoke that is less than 5% opacity. You won't see smoke from a modern trash-to-energy plant although in colder weather you will see water vapor condensation, similar to seeing your breath on a cold day. This is not considered opacity. We have a permit limit established by the Massachusetts Department of Environmental Protection of 10% opacity averaged every six (6) minutes.

Limit 10 %

Time (hr)	1-6 min	7-12 min	13-18 min	19-24 min	25-30 min	31-36 min	37-42 min	43-48 min	49-54 min	55-60 min	Average
0	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1
2	1	1	1	1	1	1	1	1	1	1	1
3	1	1	1	1	1	1	1	1	1	1	1
4	1	1	1	1	1	1	1	1	1	1	1
5	1	1	1	1	1	1	1	1	1	1	1
6	2	IC	5	IC	1	1	1	1	1	1	1
7	1	1	1	1	1	1	1	1	1	1	1
8	1	1	1	1	1	1	1	1	1	1	1
9	1	1	1	1	1	1	1	1	1	1	1
10	1	1	1	1	1	1	1	1	1	1	1
11	1	1	1	1	1	1	1	1	1	1	1
12	1	1	1	1	1	1	1	1	1	1	1
13	1	1	1	1	1	1	1	1	1	1	1
14	1	1	1	1	1	1	1	1	1	1	1
15	1	1	1	1	1	1	1	1	1	1	1
16	1	1	1	1	1	1	1	1	1	1	1
17	1	1	1	1	1	1	1	1	1	1	1
18	1	1	1	1	1	1	1	1	1	1	1
19	1	1	1	1	1	1	1	1	1	1	1
20	1	1	1	1	1	1	1	1	1	1	1
21	1	1	1	1	1	1	1	1	1	1	1
22	1	1	1	1	1	1	1	1	1	1	1
23	1	1	1	1	1	1	1	1	1	1	1

Status Flags

I - Invalid C - Calibration F - Offline T - Out of Control ^ - Startup
 B - Bad M - Maintenance P - Purge E - Excluded * - Shutdown



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY OPACITY REPORT



Date 17-Jan-2025

Plant Wheelabrator North Andover
Unit Unit 2
Source Outlet

Opacity is a measure of how much soot or smoke may be contained in stack emissions. The more smoke that is contained in the emissions the higher the level of opacity. Continuous opacity monitors located after all of the air pollution control equipment measure the opacity of the emissions from each boiler. Typically the human eye can not detect or see smoke that is less than 5% opacity. You won't see smoke from a modern trash-to-energy plant although in colder weather you will see water vapor condensation, similar to seeing your breath on a cold day. This is not considered opacity. We have a permit limit established by the Massachusetts Department of Environmental Protection of 10% opacity averaged every six (6) minutes.

Limit 10 %

Time (hr)	1-6 min	7-12 min	13-18 min	19-24 min	25-30 min	31-36 min	37-42 min	43-48 min	49-54 min	55-60 min	Average
0	1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1	1
2	1	1	1	1	1	1	1	1	1	1	1
3	1	1	1	1	1	1	1	1	1	1	1
4	1	1	1	1	1	1	1	1	1	1	1
5	1	1	1	1	1	1	1	1	1	1	1
6	1	IC	5	IC	1	1	1	1	1	1	1
7	1	1	1	1	1	1	1	1	1	1	1
8	1	1	1	1	1	1	1	1	1	1	1
9	1	1	1	1	1	1	1	1	1	1	1
10	1	1	1	1	1	1	1	1	1	1	1
11	1	1	1	1	1	1	1	1	1	1	1
12	1	1	1	1	1	1	1	1	1	1	1
13	1	1	1	1	1	1	1	1	1	1	1
14	1	1	1	1	1	1	1	1	1	1	1
15	1	1	1	1	1	1	1	1	1	1	1
16	1	1	1	1	1	1	1	1	1	1	1
17	1	1	1	1	1	1	1	1	1	1	1
18	1	1	1	1	1	1	1	1	1	1	1
19	1	1	1	1	1	1	1	1	1	1	1
20	1	1	1	1	1	1	1	1	1	1	1
21	1	1	1	1	1	1	1	1	1	1	1
22	1	1	1	1	1	1	1	1	1	1	1
23	1	1	1	1	1	1	1	1	1	1	1

Status Flags

I - Invalid C - Calibration F - Offline T - Out of Control ^ - Startup
 B - Bad M - Maintenance P - Purge E - Excluded * - Shutdown