



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY DRAFT - COMPLIANCE SUMMARY REPORT



Date 11/26/25

Plant Wheelabrator North Andover

NOTE: Emission & Process results may change after Startup, Shutdown, Malfunction data validation

Unit Unit 1

Source Outlet

Date	Hour	On-Line Minutes	O2		NOx		SO2					CO				Carbon Feed		FF Temp (deg F)		Steam KLbs/Hr		
			Out Vol % Dry	Status	Outlet ppm 7%O2	Status	Outlet ppm 7%O2	Status	Inlet ppm 7%O2	Status	Removal	Status	Outlet ppm 7%O2	Status	4 Hr Block	Status	Lbs/Hr Avg.	8 Hr Block	1 Hr Avg.	4 Hr Block	1 Hr Avg.	4 Hr Block
11/26/2025	0	60	10.0		138		0		50		100		0				13		314		168.6	
11/26/2025	1	60	10.1		141		0		57		100		0				13		313		167.8	
11/26/2025	2	60	10.2		142		0		48		100		0				13		315		169.1	
11/26/2025	3	60	10.5		139		0		36		100		0	0			13		314	314	164.4	167.5
11/26/2025	4	60	10.4		143		0		39		100		0				13		315		165.6	
11/26/2025	5	60	10.5		139		0		68		100		0				13		314		168.7	
11/26/2025	6	60	9.8		143		0		55		100		1				13		314		169.4	
11/26/2025	7	60	10.0		136		2		63		97		1	1		13	13	314	314	169.0	168.2	
11/26/2025	8	60	10.5		139		0		41		99		0				13		314		168.6	
11/26/2025	9	60	10.3		143		0		35		100		0				13		315		167.7	
11/26/2025	10	60	10.1		141		0		30		100		1				13		315		168.8	
11/26/2025	11	60	10.4		140		0		32		100		0	0		12		314	314	168.0	168.3	
11/26/2025	12	60	10.3		141		0		34		100		0				13		314		167.5	
11/26/2025	13	60	10.0		142		0		36		100		1				13		315		168.0	
11/26/2025	14	60	9.7		142		0		25		100		2				13		315		168.6	
11/26/2025	15	60	9.8		141		0		17		100		1	1		13	13	314	314	164.4	167.1	
11/26/2025	16	60	10.1		140		0		17		100		0				13		314		165.9	
11/26/2025	17	60	9.9		142		0		28		100		1				13		314		168.0	
11/26/2025	18	60	9.5		141		0		28		100		1				13		314		168.3	
11/26/2025	19	60	9.6		140		0		24		100		1	1		13		314	314	168.2	167.6	
11/26/2025	20	60	10.1		139		0		26		100		0				13		314		167.6	
11/26/2025	21	60	10.0		141		0		33		100		0				13		315		169.7	
11/26/2025	22	60	10.3		140		3		49		94		0				13		314		165.6	
11/26/2025	23	60	10.3		142		4		45		90		0	0		13	13	314	314	166.7	167.4	

Average:
Geometric Mean Average:

141	0
≤ 150 24-HR Block Avg.	≤ 29 24-HR Geometric Mean

100
≥ 80% Removal Efficiency

OR

see above
≤ 69 ppmc 4-HR Block Average

see above
≥ 12 lb/hr 8-HR. Block Average

see above
≤ 345 °F 4-HR Block Average

see above
≤ 173 klb/hr 4-HR Block Average

Status Flags

- I - Invalid
- B - Bad
- C - Calibration
- M - Maintenance
- F - Offline
- P - Purge
- T - Out of Control
- E - Excluded
- ^ - Startup
- * - Shutdown



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY DRAFT - COMPLIANCE SUMMARY REPORT



Date 11/26/25

Plant Wheelabrator North Andover

NOTE: Emission & Process results may change after Startup, Shutdown, Malfunction data validation

Unit Unit 2

Source Outlet

Date	Hour	On-Line Minutes	O2		NOx		SO2					CO			Carbon Feed		FF Temp (deg F)		Steam KLbs/Hr		
			Out Vol % Dry	Status	Outlet ppm 7%O2	Status	Outlet ppm 7%O2	Status	Inlet ppm 7%O2	Status	Removal	Status	Outlet ppm 7%O2	Status	4 Hr Block	Status	Lbs/Hr Avg.	8 Hr Block	1 Hr Avg.	4 Hr Block	1 Hr Avg.
11/26/2025	0	60	11.0		140		2		72		97		6			13		315		168.2	
11/26/2025	1	60	11.0		139		0		58		100		6			13		315		167.5	
11/26/2025	2	60	11.0		139		1		61		99		6			14		315		168.6	
11/26/2025	3	60	11.1		141		0		55		100		5	6		13		315	315	167.7	168.0
11/26/2025	4	60	11.0		141		0		62		100		8			13		315		168.2	
11/26/2025	5	60	11.1		139		0		50		100		5			13		315		168.0	
11/26/2025	6	60	10.9		140		0		58		100		6			14		315		168.7	
11/26/2025	7	60	11.0		139		0		56		100		6	6		12	13	315	315	168.2	168.3
11/26/2025	8	60	10.9		139		3		51		95		6			13		315		167.4	
11/26/2025	9	60	11.0		139		0		45		100		5			14		316		169.3	
11/26/2025	10	60	11.3		141		0		33		100		5			13		315		168.8	
11/26/2025	11	60	11.1		138		0		40		100		5	5		12		315	315	168.6	168.5
11/26/2025	12	60	11.0		141		0		39		100		5			13		315		168.8	
11/26/2025	13	60	10.7		139		0		47		100		6			13		315		168.5	
11/26/2025	14	60	10.6		140		0		38		100		6			13		315		168.4	
11/26/2025	15	60	10.7		138		0		30		100		5	6		13	13	315	315	165.9	167.9
11/26/2025	16	60	11.1		140		0		34		100		5			14		314		166.4	
11/26/2025	17	60	11.0		140		0		46		100		6			13		315		167.6	
11/26/2025	18	60	10.8		141		0		43		100		6			13		315		169.1	
11/26/2025	19	60	10.9		138		0		45		100		5	6		13		315	315	167.8	167.7
11/26/2025	20	60	11.1		140		0		49		99		5			14		315		166.8	
11/26/2025	21	60	11.0		139		1		54		98		5			13		315		168.6	
11/26/2025	22	60	11.2		139		1		57		97		4			13		315		166.6	
11/26/2025	23	60	11.0		140		4		65		94		4	4		13	13	315	315	168.6	167.7

Average:
Geometric Mean Average:

Limit:

140	0
≤ 150 24-HR Block Avg.	≤ 29 24-HR Geometric Mean

OR

100
≥ 80% Removal Efficiency

see above
≤ 69 ppmc 4-HR Block Average

see above
≥ 12 lb/hr 8-HR. Block Average

see above
≤ 345 °F 4-HR Block Average

see above
≤ 173 klb/hr 4-HR Block Average

Status Flags

- I - Invalid
- B - Bad
- C - Calibration
- M - Maintenance
- F - Offline
- P - Purge
- T - Out of Control
- E - Excluded
- ^ - Startup
- * - Shutdown



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY OPACITY REPORT



Date 26-Nov-2025

Plant Wheelabrator North Andover
Unit Unit 1
Source Outlet

Opacity is a measure of how much soot or smoke may be contained in stack emissions. The more smoke that is contained in the emissions the higher the level of opacity. Continuous opacity monitors located after all of the air pollution control equipment measure the opacity of the emissions from each boiler. Typically the human eye can not detect or see smoke that is less than 5% opacity. You won't see smoke from a modern trash-to-energy plant although in colder weather you will see water vapor condensation, similar to seeing your breath on a cold day. This is not considered opacity. We have a permit limit established by the Massachusetts Department of Environmental Protection of 10% opacity averaged every six (6) minutes.

Limit 10 %

Time (hr)	1-6 min	7-12 min	13-18 min	19-24 min	25-30 min	31-36 min	37-42 min	43-48 min	49-54 min	55-60 min	Average
0	2	2	2	2	2	2	2	2	2	2	2
1	2	2	2	2	2	2	2	2	2	2	2
2	2	2	2	2	2	2	2	2	2	2	2
3	2	2	2	2	2	2	2	2	2	2	2
4	2	2	2	2	2	2	2	2	2	2	2
5	2	2	2	2	2	2	2	2	2	2	2
6	2	IC	6	IC	2	2	2	2	2	2	2
7	2	2	2	2	2	2	2	2	2	2	2
8	2	2	2	2	2	2	2	2	2	2	2
9	2	2	2	2	2	2	2	2	2	2	2
10	2	2	2	2	2	2	2	2	2	2	2
11	2	2	2	2	2	2	2	2	2	2	2
12	2	2	2	2	2	2	2	2	2	2	2
13	2	2	2	2	2	2	2	2	2	2	2
14	2	2	2	2	2	2	2	2	2	2	2
15	2	2	2	2	2	2	2	2	2	2	2
16	2	2	2	2	2	2	2	2	2	2	2
17	2	2	2	2	2	2	2	2	2	2	2
18	2	2	2	2	2	2	2	2	2	2	2
19	2	2	2	2	2	2	2	2	2	2	2
20	2	2	2	2	2	2	2	2	2	2	2
21	2	2	2	2	2	2	2	2	2	2	2
22	2	2	2	2	2	2	2	2	2	2	2
23	2	2	2	2	2	2	2	2	2	2	2

Status Flags

I - Invalid C - Calibration F - Offline T - Out of Control ^ - Startup
 B - Bad M - Maintenance P - Purge E - Excluded * - Shutdown



WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY OPACITY REPORT



Date 26-Nov-2025

Plant Wheelabrator North Andover
Unit Unit 2
Source Outlet

Opacity is a measure of how much soot or smoke may be contained in stack emissions. The more smoke that is contained in the emissions the higher the level of opacity. Continuous opacity monitors located after all of the air pollution control equipment measure the opacity of the emissions from each boiler. Typically the human eye can not detect or see smoke that is less than 5% opacity. You won't see smoke from a modern trash-to-energy plant although in colder weather you will see water vapor condensation, similar to seeing your breath on a cold day. This is not considered opacity. We have a permit limit established by the Massachusetts Department of Environmental Protection of 10% opacity averaged every six (6) minutes.

Limit 10 %

Time (hr)	1-6 min	7-12 min	13-18 min	19-24 min	25-30 min	31-36 min	37-42 min	43-48 min	49-54 min	55-60 min	Average
0	2	2	2	2	2	2	2	2	2	2	2
1	2	2	2	2	2	2	2	2	2	2	2
2	2	2	2	2	2	2	2	2	2	2	2
3	2	2	2	2	2	2	2	2	2	2	2
4	2	2	2	2	2	2	2	2	2	2	2
5	2	2	2	2	2	2	2	2	2	2	2
6	1	IC	6	IC	2	2	2	2	2	2	2
7	2	2	2	2	2	2	2	2	2	2	2
8	2	2	2	2	2	2	2	2	2	2	2
9	2	2	2	2	2	2	2	2	2	2	2
10	2	2	2	2	2	2	2	2	2	2	2
11	2	2	2	2	2	2	2	2	2	2	2
12	2	2	2	2	2	2	2	2	2	2	2
13	2	2	2	2	2	2	2	2	2	2	2
14	2	2	2	2	2	2	2	2	2	2	2
15	2	2	2	2	2	2	2	2	2	2	2
16	2	2	2	2	2	2	2	2	2	2	2
17	2	2	2	2	2	2	2	2	2	2	2
18	2	2	2	2	2	2	2	2	2	2	2
19	2	2	2	2	2	2	2	2	2	2	2
20	2	2	2	2	2	2	2	2	2	2	2
21	2	2	2	2	2	2	2	2	2	2	2
22	2	2	2	2	2	2	2	2	2	2	2
23	2	2	2	2	2	2	2	2	2	2	2

Status Flags

I - Invalid C - Calibration F - Offline T - Out of Control ^ - Startup
 B - Bad M - Maintenance P - Purge E - Excluded * - Shutdown