



# WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY DRAFT - COMPLIANCE SUMMARY REPORT



Date 1/17/26

Plant Wheelabrator North Andover

NOTE: Emission & Process results may change after Startup, Shutdown, Malfunction data validation

Unit Unit 1  
Source Outlet

Date	Hour	On-Line Minutes	O2		NOx		SO2					CO			Carbon Feed		FF Temp (deg F)		Steam KLbs/Hr		
			Out Vol % Dry	Status	Outlet ppm 7%O2	Status	Outlet ppm 7%O2	Status	Inlet ppm 7%O2	Status	Removal	Status	Outlet ppm 7%O2	Status	4 Hr Block	Status	Lbs/Hr Avg.	8 Hr Block	1 Hr Avg.	4 Hr Block	1 Hr Avg.
1/17/2026	0	60	10.2		154		0		12		100		0			13		315		167.6	
1/17/2026	1	60	10.5		152		0		10		100		0			14		314		167.4	
1/17/2026	2	60	10.6		141		0		14		100		0			13		314		168.2	
1/17/2026	3	60	10.6		137		0		20		100		0	0		14		314	314	167.7	167.7
1/17/2026	4	60	10.7		141		0		27		100		0			13		315		167.8	
1/17/2026	5	60	10.7		141		3		41		92		0			13		314		166.3	
1/17/2026	6	60	10.3		141		0		22		100		0			13		314		167.8	
1/17/2026	7	60	10.3		142		0		13		100		0	0		13	13	314	314	167.3	167.3
1/17/2026	8	60	10.4		139		0		20		100		0			13		314		168.9	
1/17/2026	9	60	10.5		140		0		26		100		0			13		314		167.7	
1/17/2026	10	60	10.7		142		0		23		100		0			13		315		166.4	
1/17/2026	11	60	10.4		141		0		25		100		0	0		13		314	314	165.4	167.1
1/17/2026	12	60	10.1		143		0		22		100		0			13		315		168.2	
1/17/2026	13	60	10.4		141		0		22		100		0			13		314		168.2	
1/17/2026	14	60	10.6		140		0		31		99		0			13		314		165.3	
1/17/2026	15	60	10.6		140		0		35		100		0	0		13	13	314	314	167.1	167.2
1/17/2026	16	60	10.5		142		5		49		89		0			13		314		166.4	
1/17/2026	17	60	10.6		140		0		34		99		0			13		314		165.5	
1/17/2026	18	60	10.5		143		0		32		100		0			12		315		167.8	
1/17/2026	19	60	10.6		142		0		36		99		0	0		13		314	314	167.1	166.7
1/17/2026	20	60	10.5		142		7		51		87		0			14		314		166.7	
1/17/2026	21	60	10.5		146		7		42		83		0			14		315		167.2	
1/17/2026	22	60	10.4		142		20		82		76		1			14		315		168.2	
1/17/2026	23	60	10.5		142		3		37		93		0	0		13	13	314	315	167.0	167.3

Average: Geometric Mean Average:	142	0	<b>OR</b>	100	see above	see above	see above	see above
Limit:	≤ 150 24-HR Block Avg.	≤ 29 24-HR Geometric Mean		≥ 80% Removal Efficiency	≤ 69 ppmc 4-HR Block Average	≥ 12 lb/hr 8-HR. Block Average	≤ 345 °F 4-HR Block Average	≤ 173 klb/hr 4-HR Block Average

**Status Flags**

- I - Invalid
- B - Bad
- C - Calibration
- M - Maintenance
- F - Offline
- P - Purge
- T - Out of Control
- E - Excluded
- ^ - Startup
- \* - Shutdown



# WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY DRAFT - COMPLIANCE SUMMARY REPORT



Date 1/17/26

Plant Wheelabrator North Andover

NOTE: Emission & Process results may change after Startup, Shutdown, Malfunction data validation

Unit Unit 2  
Source Outlet

Date	Hour	On-Line Minutes	O2		NOx		SO2				CO			Carbon Feed		FF Temp (deg F)		Steam KLbs/Hr			
			Out Vol % Dry	Status	Outlet ppm 7%O2	Status	Outlet ppm 7%O2	Status	Inlet ppm 7%O2	Status	Removal	Status	Outlet ppm 7%O2	Status	4 Hr Block	Status	Lbs/Hr Avg.	8 Hr Block	1 Hr Avg.	4 Hr Block	1 Hr Avg.
1/17/2026	0	60	9.9		140		0		30		100		6			15		315		168.2	
1/17/2026	1	60	10.0		138		0		36		100		5			15		315		166.9	
1/17/2026	2	60	10.2		144		0		27		100		4			14		315		166.6	
1/17/2026	3	60	10.4		139		0		33		100		5	5		14		315	315	167.8	167.4
1/17/2026	4	60	10.4		140		0		45		100		8			14		314		167.0	
1/17/2026	5	60	10.3		142		11		89		88		6			14		315		168.4	
1/17/2026	6	60	10.4		142		0		39		100		6			14		315		167.5	
1/17/2026	7	60	10.2		136		0		33		100		6	6		14	14	315	315	167.5	167.6
1/17/2026	8	60	10.3		137		0		42		100		5			14		315		167.2	
1/17/2026	9	60	10.2		140		1		46		99		6			14		315		167.6	
1/17/2026	10	60	10.3		140		0		39		100		6			14		315		167.6	
1/17/2026	11	60	10.0		140		9		68		87		6	6		14		315	315	167.7	167.5
1/17/2026	12	60	10.0		137		2		48		96		6			14		315		167.7	
1/17/2026	13	60	10.3		141		1		62		99		7			14		315		166.9	
1/17/2026	14	60	10.3		139		1		57		98		6			14		315		168.0	
1/17/2026	15	60	10.3		138		5		65		93		7	7		14	14	315	315	168.2	167.7
1/17/2026	16	60	10.3		139		18		86		79		7			14		315		167.8	
1/17/2026	17	60	10.3		142		1		52		97		6			14		315		167.0	
1/17/2026	18	60	10.2		139		7		63		90		6			13		315		167.6	
1/17/2026	19	60	10.3		141		18		94		81		8	7		13		315	315	167.5	167.5
1/17/2026	20	60	10.5		137		22		108		80		11			13		315		167.5	
1/17/2026	21	60	10.2		142		11		69		84		6			13		315		168.2	
1/17/2026	22	60	10.3		140		15		81		82		6			13		315		166.8	
1/17/2026	23	60	10.2		139		18		86		80		6	7		13	13	315	315	168.0	167.6

Average:	<b>140</b>	<b>1</b>	<b>99</b>	<b>see above</b>	<b>see above</b>	<b>see above</b>
Geometric Mean Average:						
Limit:	<b>≤ 150</b> 24-HR Block Avg.	<b>≤ 29</b> 24-HR Geometric Mean	<b>OR</b>	<b>≥ 80%</b> Removal Efficiency	<b>≤ 69</b> ppmc 4-HR Block Average	<b>≥ 12</b> lb/hr 8-HR. Block Average
					<b>≤ 345</b> °F 4-HR Block Average	<b>≤ 173</b> klb/hr 4-HR Block Average

**Status Flags**

- I - Invalid
- B - Bad
- C - Calibration
- M - Maintenance
- F - Offline
- P - Purge
- T - Out of Control
- E - Excluded
- ^ - Startup
- \* - Shutdown



# WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY OPACITY REPORT



Date 17-Jan-2026

Plant Wheelabrator North Andover  
Unit Unit 1  
Source Outlet

Opacity is a measure of how much soot or smoke may be contained in stack emissions. The more smoke that is contained in the emissions the higher the level of opacity. Continuous opacity monitors located after all of the air pollution control equipment measure the opacity of the emissions from each boiler. Typically the human eye can not detect or see smoke that is less than 5% opacity. You won't see smoke from a modern trash-to-energy plant although in colder weather you will see water vapor condensation, similar to seeing your breath on a cold day. This is not considered opacity. We have a permit limit established by the Massachusetts Department of Environmental Protection of 10% opacity averaged every six (6) minutes.

Limit 10 %

Time (hr)	1-6 min	7-12 min	13-18 min	19-24 min	25-30 min	31-36 min	37-42 min	43-48 min	49-54 min	55-60 min	Average
0	0	0	0	0	0	0	0	0	0	0	0
1	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0
4	0	0	0	0	0	0	0	0	0	0	0
5	0	0	0	0	0	0	0	0	0	0	0
6	2	IC	5	IC	0	0	0	0	0	0	1
7	0	0	0	0	0	0	0	0	0	0	0
8	0	0	0	0	0	0	0	0	0	0	0
9	0	0	0	0	0	0	0	0	0	0	0
10	0	0	0	0	0	0	0	0	0	0	0
11	0	0	0	0	0	0	0	0	0	0	0
12	0	0	0	0	0	0	0	0	0	0	0
13	0	0	0	0	0	0	0	0	0	0	0
14	0	0	0	0	0	0	0	0	0	0	0
15	0	0	0	0	0	0	0	0	0	0	0
16	0	0	0	0	0	0	0	0	0	0	0
17	0	0	0	0	0	0	0	0	0	0	0
18	0	0	0	0	0	0	0	0	0	0	0
19	0	0	0	0	0	0	0	0	0	0	0
20	0	0	0	0	0	0	0	0	0	0	0
21	0	0	0	0	0	0	0	0	0	0	0
22	0	0	0	0	0	0	0	0	0	0	0
23	0	0	0	0	0	0	0	0	0	0	0

**Status Flags**

I - Invalid                      C - Calibration                      F - Offline                      T - Out of Control                      ^ - Startup  
 B - Bad                              M - Maintenance                      P - Purge                      E - Excluded                      \* - Shutdown



# WHEELABRATOR NORTH ANDOVER A WIN-WASTE INNOVATIONS COMPANY OPACITY REPORT



Date 17-Jan-2026

Plant Wheelabrator North Andover  
Unit Unit 2  
Source Outlet

Opacity is a measure of how much soot or smoke may be contained in stack emissions. The more smoke that is contained in the emissions the higher the level of opacity. Continuous opacity monitors located after all of the air pollution control equipment measure the opacity of the emissions from each boiler. Typically the human eye can not detect or see smoke that is less than 5% opacity. You won't see smoke from a modern trash-to-energy plant although in colder weather you will see water vapor condensation, similar to seeing your breath on a cold day. This is not considered opacity. We have a permit limit established by the Massachusetts Department of Environmental Protection of 10% opacity averaged every six (6) minutes.

Limit 10 %

Time (hr)	1-6 min	7-12 min	13-18 min	19-24 min	25-30 min	31-36 min	37-42 min	43-48 min	49-54 min	55-60 min	Average
0	2	2	2	2	2	2	2	2	2	2	2
1	2	2	2	2	2	2	2	2	2	2	2
2	2	2	2	2	2	2	2	2	2	2	2
3	2	2	2	2	2	2	2	2	2	2	2
4	2	2	2	2	2	2	2	2	2	2	2
5	2	2	2	2	2	2	2	2	2	2	2
6	2	IC	6	IC	2	2	2	2	2	2	2
7	2	2	2	2	2	2	2	2	2	2	2
8	2	2	2	2	2	2	2	2	2	2	2
9	2	2	2	2	2	2	2	2	2	2	2
10	2	2	2	2	2	2	2	2	2	2	2
11	2	2	2	2	2	2	2	2	2	2	2
12	2	2	2	2	2	2	2	2	2	2	2
13	2	2	2	2	2	2	2	2	2	2	2
14	2	2	2	2	2	2	2	2	2	2	2
15	2	2	2	2	2	2	2	2	2	2	2
16	2	2	2	2	2	2	2	2	2	2	2
17	2	2	2	2	2	2	2	2	2	2	2
18	2	2	2	2	2	2	2	2	2	2	2
19	2	2	2	2	2	2	2	2	2	2	2
20	2	2	2	2	2	2	2	2	2	2	2
21	2	2	2	2	2	2	2	2	2	2	2
22	2	2	2	2	2	2	2	2	2	2	2
23	2	2	2	2	2	2	2	2	2	2	2

**Status Flags**

I - Invalid                      C - Calibration                      F - Offline                      T - Out of Control                      ^ - Startup  
 B - Bad                            M - Maintenance                      P - Purge                      E - Excluded                      \* - Shutdown