

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSION AND MONITORING SYSTEM PERFORMANCE

COMPANY: Wheelabrator North Andover Inc.
ADDRESS: 285 Holt Road
 North Andover, MA 01845

**IMPLEMENTING EXCLUSION OF DATA DURING STARTUP,
 SHUTDOWN AND MALFUNCTION IN ACCORDANCE WITH TITLE V AIR QUALITY
 OPERATING PERMIT TABLE 3, FOOTNOTE 10 AND TABLE 6, ITEM 4**

QUARTER: First Quarter 2016

PROCESS UNIT DESCRIPTION: MUNICIPAL SOLID WASTE RESOURCE RECOVERY FACILITY

POLLUTANT:	UNIT #1 SO ₂ OUTLET	UNIT #1 NOx	UNIT #1 CO	UNIT #1 SO ₂ RE	UNIT #1 OPACITY
REPORTING PERIOD DATES:	1/1/2016		through	3/31/2016	
EMISSION LIMITATION:	75% or 29 ppmc SO ₂	205 ppmc NOx	69 ppmc CO	75% or 29 ppmc SO ₂	10%
MONITOR MFG. & PRIMARY COMPONENTS:	EcoChem MC3	EcoChem MC3	EcoChem MC3	Western Research 721AT2	Land MK4500II
DATE OF LATEST CEMS CERTIFICATION AUDIT:	December 2010	December 2010	December 2010		
TOTAL SOURCE OPERATING TIME IN REPORTING PERIOD:	2184.0	2184.0	2184.0	2184.0	131040
EMISSION DATA SUMMARY *					
DURATION OF EXCESS EMISSIONS IN REPORTING DUE TO:					
A. STARTUP/SHUTDOWN	0	0	0	N/A	0
B. CONTROL EQUIPMENT PROBLEMS	0	0	0	N/A	0
C. PROCESS PROBLEMS	0	0	0	N/A	0
D. OTHER KNOWN CAUSES	0	0	0	N/A	0
E. UNKNOWN CAUSES	0	0	0	N/A	0
TOTAL DURATION OF EXCESS EMISSION	0	0	0	N/A	0
TOTAL DURATION OF EXCESS EMISSION	0.0%	0.0%	0.0%	N/A	0.0%
TOTAL SOURCE OPERATING TIME					
CEMS PERFORMANCE SUMMARY					
CEMS DOWNTIME IN REPORTING PERIOD DUE TO:					
A. MONITOR EQUIPMENT MALFUNCTIONS	41	41	41	0	0
B. NON-MONITOR EQUIPMENT MALFUNCTIONS	0	0	0	2	0
C. QUALITY ASSURANCE CALIBRATION	0	0	0	0	144
D. OTHER KNOWN CAUSES	0	0	0	9	36
E. UNKNOWN CAUSES	0	0	0	0	0
TOTAL CEMS DOWNTIME	41	41	41	11	180
TOTAL CEMS DOWNTIME	1.9%	1.9%	1.9%	0.5%	0.14%
TOTAL SOURCE OPERATING TIME					
DESCRIBE ANY CHANGES SINCE LAST QUARTER IN CEMS, PROCESS OR CONTROLS:					

* Record gaseous excess emissions in hours. Record excess opacity emissions in minutes

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSION AND MONITORING SYSTEM PERFORMANCE

COMPANY: Wheelabrator North Andover Inc.
ADDRESS: 285 Holt Road
 North Andover, MA 01845

**IMPLEMENTING DISMISSAL AND EXCLUSION OF DATA DURING STARTUP,
 SHUTDOWN AND MALFUNCTION IN ACCORDANCE WITH TITLE V AIR QUALITY
 OPERATING PERMIT TABLE 3, FOOTNOTE 10 AND TABLE 6, ITEM 4**

QUARTER: First Quarter 2016

PROCESS UNIT DESCRIPTION: MUNICIPAL SOLID WASTE RESOURCE RECOVERY FACILITY

	POLLUTANT:	UNIT #2 SO2 OUTLET	UNIT #2 NOx	UNIT #2 CO	UNIT #2 SO2 RE	UNIT #2 OPACITY
	REPORTING PERIOD DATES:	1/1/2016 through 3/31/2016				
	EMISSION LIMITATION:	75% or 29 ppmc SO ₂	205 ppmc NOx	69 ppmc CO	75% or 29 ppmc SO ₂	10%
	MONITOR MFG. & PRIMARY COMPONENTS:	EcoChem MC3	EcoChem MC3	EcoChem MC3	Western Research 721AT2	Land MK4500II
	DATE OF LATEST CEMS CERTIFICATION AUDIT:	December 2010	December 2010	December 2010		
	TOTAL SOURCE OPERATING TIME IN REPORTING PERIOD:	2184.0	2184.0	2184.0	2184.0	131040
EMISSION DATA SUMMARY *						
DURATION OF EXCESS EMISSIONS IN REPORTING DUE TO:						
A. STARTUP/SHUTDOWN		0	0	0	N/A	0
B. CONTROL EQUIPMENT PROBLEMS		0	0	0	N/A	0
C. PROCESS PROBLEMS		0	0	0	N/A	0
D. OTHER KNOWN CAUSES		0	0	0	N/A	0
E. UNKNOWN CAUSES		0	0	0	N/A	0
TOTAL DURATION OF EXCESS EMISSION		0	0	0	N/A	0
TOTAL DURATION OF EXCESS EMISSION		0.0%	0.0%	0.0%	N/A	0.0%
TOTAL SOURCE OPERATING TIME						
CEMS PERFORMANCE SUMMARY						
CEMS DOWNTIME IN REPORTING PERIOD DUE TO:						
A. MONITOR EQUIPMENT MALFUNCTIONS		29	29	29	0	0
B. NON-MONITOR EQUIPMENT MALFUNCTIONS		0	0	0	5	0
C. QUALITY ASSURANCE CALIBRATION		0	0	0	0	192
D. OTHER KNOWN CAUSES		7	7	7	5	150
E. UNKNOWN CAUSES		0	0	0	0	0
TOTAL CEMS DOWNTIME		36	36	36	10	342
TOTAL CEMS DOWNTIME		1.6%	1.6%	1.6%	0.5%	0.26%
TOTAL SOURCE OPERATING TIME						
DESCRIBE ANY CHANGES SINCE LAST QUARTER IN CEMS, PROCESS OR CONTROLS:						

* Record gaseous excess emissions in hours. Record excess opacity emissions in minutes