

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSION AND MONITORING SYSTEM PERFORMANCE

COMPANY: Wheelabrator North Andover Inc.
ADDRESS: 285 Holt Road
 North Andover, MA 01845

**IMPLEMENTING EXCLUSION OF DATA DURING STARTUP,
 SHUTDOWN AND MALFUNCTION IN ACCORDANCE WITH TITLE V AIR QUALITY
 OPERATING PERMIT TABLE 3, FOOTNOTE 10 AND TABLE 6, ITEM 4**

QUARTER: Third Quarter 2018

PROCESS UNIT DESCRIPTION: MUNICIPAL SOLID WASTE RESOURCE RECOVERY FACILITY

POLLUTANT:	UNIT #1 SO ₂ OUTLET	UNIT #1 NOx	UNIT #1 CO	UNIT #1 SO ₂ RE	UNIT #1 OPACITY
REPORTING PERIOD DATES:	7/1/2018		through	9/30/2018	
EMISSION LIMITATION:	75% or 29 ppmc SO ₂	205 ppmc NOx	69 ppmc CO	75% or 29 ppmc SO ₂	10%
MONITOR MFG. & PRIMARY COMPONENTS:	EcoChem MC3	EcoChem MC3	EcoChem MC3	Western Research 721AT2	Durag D-R 290G2
DATE OF LATEST CEMS CERTIFICATION AUDIT:	December 2010	December 2010	December 2010		
TOTAL SOURCE OPERATING TIME IN REPORTING PERIOD:	2028.0	2028.0	2028.0	2028.0	121677
EMISSION DATA SUMMARY *					
DURATION OF EXCESS EMISSIONS IN REPORTING DUE TO:					
A. STARTUP/SHUTDOWN	0	0	0	N/A	0
B. CONTROL EQUIPMENT PROBLEMS	0	0	0	N/A	0
C. PROCESS PROBLEMS	0	0	16	N/A	0
D. OTHER KNOWN CAUSES	0	0	0	N/A	0
E. UNKNOWN CAUSES	0	0	0	N/A	0
TOTAL DURATION OF EXCESS EMISSION	0	0	16	N/A	0
<u>TOTAL DURATION OF EXCESS EMISSION</u> TOTAL SOURCE OPERATING TIME	0.0%	0.0%	0.8%	N/A	0.0%
CEMS PERFORMANCE SUMMARY					
CEMS DOWNTIME IN REPORTING PERIOD DUE TO:					
A. MONITOR EQUIPMENT MALFUNCTIONS	0	0	0	0	0
B. NON-MONITOR EQUIPMENT MALFUNCTIONS	0	0	0	0	0
C. QUALITY ASSURANCE CALIBRATION	1	1	1	2	174
D. OTHER KNOWN CAUSES	2	2	2	6	954
E. UNKNOWN CAUSES	0	0	0	0	0
TOTAL CEMS DOWNTIME	3	3	3	8	1128
<u>TOTAL CEMS DOWNTIME</u> TOTAL SOURCE OPERATING TIME	0.1%	0.1%	0.1%	0.4%	0.93%
DESCRIBE ANY CHANGES SINCE LAST QUARTER IN CEMS, PROCESS OR CONTROLS:					Certified new COMS on 12/25/2017

* Record gaseous excess emissions in hours. Record excess opacity emissions in minutes

SUMMARY REPORT - GASEOUS AND OPACITY EXCESS EMISSION AND MONITORING SYSTEM PERFORMANCE

COMPANY: Wheelabrator North Andover Inc.
ADDRESS: 285 Holt Road
 North Andover, MA 01845

**IMPLEMENTING DISMISSAL AND EXCLUSION OF DATA DURING STARTUP,
 SHUTDOWN AND MALFUNCTION IN ACCORDANCE WITH TITLE V AIR QUALITY
 OPERATING PERMIT TABLE 3, FOOTNOTE 10 AND TABLE 6, ITEM 4**

QUARTER: Third Quarter 2018
PROCESS UNIT DESCRIPTION: MUNICIPAL SOLID WASTE RESOURCE RECOVERY FACILITY

	POLLUTANT:	UNIT #2 SO2 OUTLET	UNIT #2 NOx	UNIT #2 CO	UNIT #2 SO2 RE	UNIT #2 OPACITY
	REPORTING PERIOD DATES:	7/1/2018 through 9/30/2018				
	EMISSION LIMITATION:	75% or 29 ppmc SO ₂	205 ppmc NOx	69 ppmc CO	75% or 29 ppmc SO ₂	10%
	MONITOR MFG. & PRIMARY COMPONENTS:	EcoChem MC3	EcoChem MC3	EcoChem MC3	Western Research 721AT2	Durag D-R 290G2
	DATE OF LATEST CEMS CERTIFICATION AUDIT:	December 2010	December 2010	December 2010		
	TOTAL SOURCE OPERATING TIME IN REPORTING PERIOD:	2103.8	2103.8	2103.8	2103.8	126227
EMISSION DATA SUMMARY *						
DURATION OF EXCESS EMISSIONS IN REPORTING DUE TO:						
A. STARTUP/SHUTDOWN		0	0	0	N/A	0
B. CONTROL EQUIPMENT PROBLEMS		0	0	0	N/A	0
C. PROCESS PROBLEMS		0	0	0	N/A	0
D. OTHER KNOWN CAUSES		0	24	0	N/A	0
E. UNKNOWN CAUSES		0	0	0	N/A	0
TOTAL DURATION OF EXCESS EMISSION		0	24	0	N/A	0
TOTAL DURATION OF EXCESS EMISSION		0.0%	1.1%	0.0%	N/A	0.0%
TOTAL SOURCE OPERATING TIME						
CEMS PERFORMANCE SUMMARY						
CEMS DOWNTIME IN REPORTING PERIOD DUE TO:						
A. MONITOR EQUIPMENT MALFUNCTIONS		0	0	0	0	0
B. NON-MONITOR EQUIPMENT MALFUNCTIONS		0	0	0	28	0
C. QUALITY ASSURANCE CALIBRATION		1	1	1	0	150
D. OTHER KNOWN CAUSES		4	4	4	192	690
E. UNKNOWN CAUSES		0	0	0	0	0
TOTAL CEMS DOWNTIME		5	5	5	220	840
TOTAL CEMS DOWNTIME		0.2%	0.2%	0.2%	10.4%	0.67%
TOTAL SOURCE OPERATING TIME						
DESCRIBE ANY CHANGES SINCE LAST QUARTER IN CEMS, PROCESS OR CONTROLS:						Certified new COMS on 12/25/2017

* Record gaseous excess emissions in hours. Record excess opacity emissions in minutes